

26 20 00 LOW VOLTAGE

PART 1: PRODUCTS

1.01 Wiring Devices

A. Electrical Requirements

1. Minimum 20 ampere rated switches shall be used for lighting and power loads. In cases where wall dimmers are used, the dimmer shall be solid-state design with flicker noise control. Minimum accepted manufacturer and quality – Lutron Nova T Series.

1.02 Disconnect Switches

- A. Use heavy duty type fused and non-fused, enclosed switches only.

1.03 Metal Enclosed Distribution Switchgear

- A. Preferred use ANSI C37.15/UL1066, draw out mounted, power circuit breakers in the switchgear.

B. Metering:

1. Coordinate location of sub-metering & requirements with SHSU.

1.04 Panel boards

- A. All panel boards shall have door locks. The front cover shall be a door in door arrangement with the inner door hinged to allow breaker handle access.

26 29 00 LOW VOLTAGE CONTROLLERS

26 30 00 POWER GENERATING EQUIPMENT

PART 1: GENERAL

1.03 Emergency System

1. Fire pumps shall be connected to the emergency system per applicable codes.

26 50 00 LIGHTING

PART 1: GENERAL

1.01 LUMINAIRES

A. All luminaires are preferred to be listed on the Design Lighting Consortium.

B.

Do -11 ET 61.08 6 (87Tj ET EMC BT /3.7 (t0)-75(1)-3.9CRE 0.26 (i.2 (r.2 (9 (d))T

5. Preferred, All Edison or medium base lamps to be LED. Interior shall be 2700K, Exterior shall 4700K, 100/277V.

6. Alternate, Screw and plug-in compact type fluorescent lamps installed within conditioned spaces shall have a minimum rated lamp life of 10,000 hours at 3 hours/start, CCT of 5000K and ETK: 20EHU. They shall have the additional requirement of being operated by an electronic ballast designed for unconditioned spaces.

A. Ballasts for linear lamps.

1. Fluorescent ballasts shall be high frequency (see item 12 below), U.L. approved, CBM certified to operate as specified one, two or three T8 lamps

2. Shall be program start and classified as NEMA premium efficiency

3. Shall be designed

4. Shall be tested in accordance with LM-80 lumen depreciation test. Provide to the University, test results of each unique lamp. The L70 rated life result shall be a minimum of 25,000 hours for MR11, 16 and candelabra lamps; 40,000 hours for PAR 20, 30, 38 and BR30 lamps.

B. Power Supplies

1. Dimmable power supplies shall allow the light output to be maintained at the lowest control setting (prior to off) without dropping out.

C. Exit Signs

**SAM HOUSTON STATE UNIVERSITY
DIVISION 26 ELECTRICAL**

SECTION 260000 ELECTRICAL