## Historically Underutilized Business Program

Sam Houston State University/frice of Facilities Planning and Constructioncommitted to promoting the participation of minority, womeowned, and smalbusinesses through the Historically Underutilized Business (HUB) Program for those ocurement of goods and/or services. The procurement process utilized by the SHSU seeks to provide equal opportunity and equal access in the designstand tion opportunities on projects managed by Facilities Planning and Construction.

## **General Information**

The "Design and Construction Standardsintended as guidance for the project hitect/engineer team and the contractor team during the design and constructioness for The am Houston State University Capital Projects. The content covers specific design criteria, the design process and administrative procedures for permanebutildings on SHSUS ubsets of this document will pertain to reniovatcivil, etc. type projects. Many but not all requirements for each CampAgeoncy of SHSU are covered. The Project A/E, CMAR or DB shall also refeto items covered in their Services Agreement and in the project's Program of Requirements (POR).

The "Design and Construction Standards" all be used along with the project specific Program of Requirements and the Services Agreement.

In the event of conflict between contractdabument and specific project requirements the more stringent requirements hall apply. The A/E,CMAR or D-B shall contact the Project Manager with

FTd [3-1.-4.7 (he)-1.6 (.6 (.w 5.228 02y6 0 Td he)-1.60.0161Tw [(CMTw) 2netheds Tsyls (Berns, 4.7 (he)-1.)2eE .6 (. products or devices notivered in this document. All alternatives all be documented by the A/E, CMAR and DB and submitted to the Project Manager approval by Facilities Planning & Construction prior to implementation.

**Design Philosophy** 

**Design Quality** 

Building HVAC systems, and ElectricaLevel of control and integration shall be determined by SHSU Facilities Management.

## Codes and Standards

Comply with all state and Federal laws applicable to construction. The Project At Eeaned Project Manager shall also cooperate with municipalities when tying into Latitaties. Archi7a002 Tw [((I)6.2 (rhi)664.6 (e)9

### **Design Basis**

- 1. Current adopted version of NFPA 101
- 2. Current adopted version International Building Code.

#### Architectural Design

- 1. SHSU Exterior Signage Standards: SEE APPENDIX I
- 2. SHSU Interior Signage Standards: SEE APPENDIX II
- 3. SHSU Room Numbering Standards: SEE APPENDIX III

#### Communications Design

1. TIA/EIA Standards

#### Permits & Submissions

The Project A/E is required to submit seadled uments for an accessibility review. The required review should be accomplished by a Registered Accessibility Specialist love the project site. The same Registered Accessible Specialist (RAS) will be utilized the plan review and the post constion inspection.

The A/E will be required to secure permits from state and federal government agencies when necessary, such as Texas Department of Highways and Public Transport **Health** Department, etc. The cost of any permits will be borne by the wner.

The Project A/E will complete and submit the Energy Conservation Design Standard Certification form for Nonresidential Buildings and compliance forms require they current adopted version ASHRAE 90.1 as part of the required Energy Report to the FPC Project Manager.

The project A/E will complete and submit the Energy Conservation Design Standard Certification form for Residential Buildings and compliance forms required by cthreent adopted version International Energy Conservation Code as roof the required energy port to the FPC Project Manager.

### **Environmental Practices**

#### **Building Materials**

Wherever possible, products, and materials with recycdedent and no or lowolatile organic compounds (VOC) shall be specified in the building design.

Material containing any measureable amount of asbestos shall not be allowed.

# SAM HOUSTON STATE UNIVERSITY 4.00.00 -BASIS OF DESIGN

The building circulation system (corridors) should be clearly designed to lead building ants from entrances to their destination. It is desirable to introduce as much natural light as possible into corridors, through windows, transmos or borrowed light. Utility systems should be routed in circulation pathways to provide access to utilities ithout disrupting occupied spaces.

Doors on opposite sides of corridors shall be offset to prevent direct viewing from conteo another. Classroom and laboratory room doors opening into corridors shall be sed the width of the door to eliminate corridor obstructions.

# SAM HOUSTON STATE UNIVERSITY 4.00.00 -BASIS OF DESIGN

handler rooms must be from within the building from the corridor system and not through any other space. Door should open out from space to maximize usable interior floor and wall area. Provide a minimum of 2 feet clearance on two sides and one end of the air handlers. **Pleavide**ce for removing coils and filters. These clearances shall be modelectfordination purposes. Air handler rooms shall be insulated for soundDepress the floor of all mechanical room\$/2 inches and uniformly slope the entire floor to minimum 4 inch floor drains connected to the building sanitary sewer system. All mechanical rooms containing HVAQpeipment shall be designed to current version of ASHRAE 15.

#### Rest Rooms

Rest rooms should be designed to provide doostess entrances if at all possible. If doors are utilized on rest room entrances they shall be equipped with automated door operators.

Rest rooms should be grouped with custodial closets for easeinotenance and to reduce plumbing runs. Either the built in trasfeceptacle shall be located adjacentherestroom door or there shall be floor space available next to the door for the placement of a large trash can.