

PART 1: GENERAL

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of SHSU for materials and products to prevent the spread of fire through openings in floors, walls, and ceilings. Refer to Section 07840.02 Related Standards.

-
- A. Compatibility of materials: All fire stopping must be a UL approved assembly.

1.03 Quality Control

- A. SHSU contact for review of fire resistive assemblies: State Fire Marshall 81 0 661
- B. For all remodels and renovations contractor shall maintain integrity of existing fire barriers.

1.04 General Requirements

- A. Labeling/identifying conditions for future modifications: On the above ceiling (concealed) surface of each side of fire rated walls, stencil in red and with 6" lettering, the rating of the wall. Labeling of each fire rated penetration above ceiling by a certified company is required.
- B. This labeling shall occur at 10' intervals.
- Each UL Listed system shall be documented with locations on As Built drawings.
- C. Asbestos: In no instance will any product containing asbestos be acceptable for use.
- D. Fire Stopping assemblies must make a smoke tight and water tight seal.