Campus Design Standards

The building design shall follow the guidelines established in the University or Agency Master Plan as well as the guidelines in this document. In the event of a conflict between standards established in a Master Plan and this document the Campus Master Plan shall govern. In lieu of master plan guidelines the design shall blend with campus standards and neighboring buildings. The design shall also conform to neighboring building setbacks, roof lines, etc.

BIM Requirements

All designs shall incorporate BIM Technology within their designs and P26(o)10.9(nf)-4e540.9(nf)-48(bui2S)15

Codes and Standards

Comply with all state and Federal laws applicable to construction. The Project A/E and FPC Project Manager shall also cooperate with municipalities when tying into local utilities. Architect and Engineer shall design to the latest codes and standards adopted at start of design.

SEE APPENDIX V & VI for City of Huntsville & SHSU Details

General Requirements

The Project A/E shall design SHSU projects to comply with the current editions of the following codes and standards and advise the Owner of code revisions having impact on the project design.

The State Fire Marshal is the code Authority Having Jurisdiction (AHJ) for all issues pertaining to NFPA 101 Life Safety Codes. FPC is responsible for facilitating resolution of conflicts and interpretations for these non-NFPA 101 codes after a thorough and joint discussion. Sam Houston State University shall designate an AHJ for all other codes and requirements.

The Project A/E shall prepare a written codes and standards analysis, “Building Code Analysis,” for each project for review by FPC. This analysis shall provide a side-by-side comparison of the requirements of the listed codes and standards. The comparison shall include all code items and an indication of which code requirement is being applied to the project. In the absence of a careful and thorough discussion by the design team of a specific conflict between the codes, the default is to design to the more stringent or robust code. These code discussions are project-specific and on an item by item basis within the codes. The final approved Building Code Analysis shall be included in the construction documents for future reference.

In the event of the need for interpretation among the codes and standards, the Project A/E shall inform FPC of the need for an interpretation and FPC will establish the requirements for compliance.

Local municipal building codes are not applicable to construction on State of Texas properties, which includes all properties owned by Sam Houston State University.

However, if it is necessary for a local authority to review any aspect of the project design, such shall be arranged by the FPC.

FPC may also require the Project A/E to comply with certain provisions from the local fire department that provides fire protection services for the University. These provisions may include locations and dimensions for firefighting access, including fire lanes; locations and specifications for standpipes, fire hose cabinets, fire control room, and fire hose connections; elevator requirements; and other similar matters.

The Project A/E shall be required to provide a statement that the project is designed in compliance with applicable codes and standards. The following statement shall be included on the general information page adjacent to the project building code summary.

"Life Safety Code Compliance: The Architect/Engineer of Record acknowledges that construction projects for Sam Houston State University must, at a minimum, be designed in accordance with the requirements of National Fire Protection Association (NFPA) 101, Life Safety Code, as currently adopted by the State Fire Marshal, Texas Government Code sec. 417.008(e). Therefore, the Architect/Engineer of Record affirms that, to the best of his/her professional judgment, knowledge, and belief, the design of this project satisfies the requirements of NFPA 101, Life Safety Code, as well as any other codes or standards made applicable to the project by the professional services agreement."

Design Basis

1. Current adopted version of NFPA 101
2. Current adopted version International Building Code.

Architectural Design

1. SHSU Exterior Signage Standards: SEE APPENDIX I
2. SHSU Interior Signage Standards: SEE APPENDIX II
3. SHSU Room Numbering Standards:dna5ele5 Td2n2 (3.)Tj /TT2 1 Tf ( )Tj /TT1 1 Tf 1.63 Tj -0.f1sw(-A82

Acoustic Design

Design in accordance with good practice to achieve conventional ambient noise levels qualified in Noise Criteria (NC) defined in current ASHRAE Applications Volume, Chapter 42 and ANSI S1.8 Reference Quantities for Acoustical Levels – ASA 84.

The ambient sound level of an occupied space is not to exceed the following NC listed for its respective typical occupancy unless specifically directed otherwise by the System Member representative or the project Program of Requirements. Spatial form, materials, assemblies, systems and equipment selections are to be designed as required to achieve a standard quality of specified level of maximum background noise.

Typical Occupancy	Maximum Noise Criteria (NC)
Apartment/Dorms	
Individual rooms/suites	50
Meeting/Banquet rooms	35
Halls, corridors & lobbies	40
Service/support areas	45
Offices	
Executive	30
Conference Rooms	30 H Re[TDauamuerence Rooms

Permits & Submissions

The Project A/E is required to submit sealed documents for an accessibility review. The required review should be accomplished by a Registered Accessibility Specialist located near the project site. The same Registered Accessible Specialist (RAS) will be utilized for the plan review and the post construction inspection.

The A/E will be required to secure permits from state and federal government agencies as necessary, such as Texas Department of Highways and Public Transportation, Health Department, etc. The cost of any permits will be borne by the Owner.

The Project A/E will complete and submit the Energy Conservation Design Standard Certification form fo

Building Materials

service tunnels, etc. are discouraged in areas subject to flooding. Should below-grade service areas or basements be required, they should not have openings located below the 500yr+2ft in areas subject to flooding, or below grade of the surrounding terrain in areas not subject to flooding.

Building Entrances

All Public entrances shall have at least one (1) complete path of entrance with a powered opener.

All exterior doors must be designed for control by the University remote access control system.

All main entry points to a building must be provided with a vestibule that performs as

Egress Stairs

The location and design of egress stairs within buildings should encourage their everyday use for vertical circulation. Magnetic door hold open devices, interconnected to the building fire alarm system, are allowed to keep interior doors to egress stairs in an open position to encourage their use.

Stairwells shall have an outlet on every landing. (Not required in residence halls)

Area of Refuge

Area of Refuge shall be provided at each level without ground access in all buildings with elevators.

Access Panels

Access Panels shall be placed to easily access equipment and shall be sized allow for the removal of the largest component of equipment being accessed through the access panel.

Roof Access

Roof access shall meet OSHA standard and shall be provided to all roof levels. Fall protection shall be provided for all roof levels that do not meet OSHA standards.

Equipment Rooms

All mechanical and electrical equipment rooms must be designed with adequate access and space and clearances around equipment to accommodate maintenance from the floor and replacement of items. There must be a defined pathway from all equipment rooms to the building exterior of adequate size to permit the replacement of equipment. Means of removal of equipment shall be by the most cost efficient path approved by the University FPO department. Plans and elevations for all equipment rooms, at a scale not less than ¼” = 1’0”, shall be prepared for each room to indicate that adequate circulation and maintenance areas are provided. The A/E shall model all requi

hangers, and room enough to store cart and floor buffer. These custodial closets should have an area of not less than fifty (50) square feet and a minimum clear width of five feet.

Custodial rooms shall be keyed to custodial master.

Custodial closet shall contain the following:

1. Standard 2'x2'x8" floor corner mounted mop sink located close to door.
2. Wall surface materials around the mop sink must be moisture resistant.
3. Floors shall be sealed concrete sloped to a minimum 4” floor drain.
4. Mop Rack – Bobrick B-224 X 30” mounted over service sink.
5. Provide 12” deep